

# TEST REPORT

(Electronic version)



No:200031546

VERIFICATION WEBSITE: [www.gttc.net.cn](http://www.gttc.net.cn)

VERIFICATION CODE: FNTY-3464-04



ISSUE DATE:2020-03-10

APPLICANT: JIANGSU JINSHAXIANG TECHNOLOGY CO.,LTD  
ADDRESS: WEST XINYU ROAD, XINQIAO TOWN, JIANGYIN, JIANGSU, CHINA

APPLICANT PROVIDED SAMPLE DESCRIPTION:  
TWENTY (20) PIECES OF DISPOSABLE MASK  
-----

DATE RECEIVED/DATE TEST STARTED: 2020-03-09

CONCLUSION:

BACTERIAL FILTRATION EFFICIENCY	M
PARTICLE FILTRATION EFFICIENCY	M


NOTE: "M" -MEET THE STANDARD'S REQUIREMENT "F" -FAIL TO MEET THE STANDARD'S REQUIREMENT  
"---" -NO COMMENT

REMARK:

THE DECISION INDICATORS ARE DERIVED FROM THE GROUP STANDARD REQUIRED BY CLIENT (T/CTCA 7-2019). OUR INSPECTION CAPACITY AUTHORIZED BY CMA AND CAL COVERS THE INSPECTION ITEMS T/CTCA 7-2019.  
ALL THE TESTED ITEMS ARE TESTED UNDER THE STANDARD CONDITION (EXCEPT FOR INDICATION).  
COPIES OF THE REPORT ARE VALID ONLY RE-STAMPED.  
THE EXPERIMENT WAS CARRIED OUT AT No.1, ZHUJIANG ROAD, PANYU DISTRICT, GUANGZHOU, GUANGDONG, P. R. CHINA.

APPROVED BY:


Ming Fang ENGINEER



# TEST REPORT

(Electronic version)

No:200031546



# TEST REPORT

(Electronic version)

No:200031546

---

## BACTERIAL FILTRATION EFFICIENCY (%)

(YY 0469-2011 ANNEX B, TEST BACTERIA: STAPHYLOCOCCUS AUREUS ATCC 6538 , TEST AREA: 40cm<sup>2</sup> , FLOW RATE: 28.3L/min, MEAN PARTICLE SIZE: 3.0 μm, RESULT OF THE POSITIVE CONTROL: 1.9×10<sup>3</sup> CFU , RESULT OF THE NEGATIVE CONTROL: <1CFU )

		REQUIREMENT
BFE <sub>1</sub>	98.8	≥95
BFE <sub>2</sub>	98.7	(T/CTCA 7-2019)
BFE <sub>3</sub>	98.6	

---

## PARTICLE FILTRATION EFFICIENCY (%)

(YY 0469-2011 5.6.2, AIR FLOW:30L/min, AEROSOL:NaCl, AEROSOL CONCENTRATION:15mg/m<sup>3</sup> , TEMP:23.1℃, RH:36.0%)

		REQUIREMENT
MINIMUM	88.4	≥80
		(T/CTCA 7-2019)

---

—End of Report—

PAGE 3 OF 3